

Thermal Equilibrium and Test Protocol for 8mm and 4mm DSR Measurements

Dr. David A. Anderson

Professor Emeritus, Penn State

J. Michael Farrar

Western Research Institute

Gerald Reinke

Andrew Hanz

MTE Services, Inc.

Gaylon Baumgardner

Sonia Serna

Paragon

Mike Anderson

The Asphalt Institute

Matthew Corrigan, P.E.

Federal Highway Administration

FHWA Asphalt Binder ETG

Baton Rouge, LA

September 16-17, 2014



Background

- ❑ High stiffness rheological measurements with 4 mm parallel plate geometry (PP) is a recent concept
 - ✓ Championed initially by WRI, picked up by others
- ❑ Attractive as result of
 - ✓ General availability of more sophisticated rheometers
 - ✓ Improvements in analytical tools that facilitate more sophisticated data analysis
 - ✓ Increased interest in basic rheology as a routine tool for specifying and characterizing asphalt
- ❑ Adoption of 4 mm PP for specification use will require an extension of the current DSR test method



Historical –

Rheological measurements SHRP era

- ❑ Mid to Upper Temperature – DSR PP
 - ✓ Early DSR's in common use had were less robust and lacked normal force capability
 - ✓ ASTM D7175/AASHTO T315 limited measurements to range where $100 \text{ Pa} > G^* < 100 \text{ MPa}$
 - ✓ Parallel plate geometry limited by machine compliance and resolution

- ❑ Lower Temperature - BBR and DTT
 - ✓ BBR 30 MPa to 1 GPa
 - ✓ DSR torsion bar research tool, not practical for spec use
 - ✓ DTT to characterize brittle, brittle-ductile failure



Recommendations from SHRP 370

- $G^* < 1 \text{ kPa}$
 - ✓ 50-mm PP
- $1.0 \text{ kPa} < G^* < 100 \text{ kPa}$
 - ✓ 25-mm PP with a 1-mm gap
- $0.1 \text{ MPa} < G^* < 30 \text{ MPa}$
 - ✓ 8-mm PP with a 2-mm
- $G^* > 30 \text{ MPa}$
 - ✓ Bending beam rheometer
 - ✓ Torsion bar geometry when



Rheological measurements - Capability

1. Upper temperature - 25 mm PP: OK
2. Intermediate temperature - 8 mm PP: repeatability issue
3. Lower temperature – BBR: OK

Property	d2s, % [*]	
	Within	Between
DSR, 25 mm, Tank	6.4	17.0
DSR, 25 mm, Original	9.0	22.0
DSR, 8 mm, PAV	13.8	40.2
BBR, S(60), PAV	7.2	17.8
BBR, m(60), PAV	2.9	6.8

* Difference at which 2 test results are suspect

4. Capabilities of 4 mm PP geometry are unknown



Task force scope

- ❑ To provide guidance for the development of 4 mm PP geometry as a tool for specification testing
 - ✓ Test development and refinement
 - ✓ Ruggedness testing
 - ✓ Identifying path for and facilitating technology transfer
 - ✓ Recommendations for a round robin program
 - ✓ Extending findings to 8 mm PP
- ❑ Scope does not include protocols for using test data
 - ✓ Acceptance and material specification requirements based on 4 mm PP beyond our scope
 - ✓ Executing RR beyond our scope and resources



Task Force work plan

- ❑ Step 1: Develop testing protocol that is appropriate for routine use and that provides data of acceptable accuracy and precision(repeatability)
 - ✓ Prepare for ruggedness testing
 - ✓ 8 and 4 mm PP geometry
- ❑ Step 2: Conduct ruggedness testing
 - ✓ More robust than typical ruggedness test
 - ✓ Include more than one laboratory
- ❑ Step 3: Conduct round robin
 - ✓ Only when have sufficient number of laboratories on-line
 - ✓ “Technology transfer” part of task force mission



Task Force - Specific Work Elements

- ❑ Step 1: Develop recommended testing protocol based on limited laboratory testing
 - ✓ Instrument standardization
 - ✓ Specimen preparation
 - ✓ Specimen conditioning – thermal equilibrium and physical hardening
 - ✓ Verification of data integrity
 - ✓ Provide rationale for protocol based on test results
- ❑ Step 1 result:
 - ✓ Prepare for formal ruggedness testing
 - ✓ Define minimum requirements for suitable rheometers



Step 1: Specific issues to be addressed

- ❑ Issues grouped by category
 1. Instrument verification-standardization
 2. Specimen preparation
 3. Conditioning prior to testing
 4. Testing sequence
 5. Linearity region
 6. Data quality
- ❑ Resolution of above issues depends on use of data
 - ✓ Point values for specification use?
 - ✓ Calculated parameter for specification use?
 - ✓ Use by producer for QC?
 - ✓ Mastercurve or model manipulation?



1. Issues – Verification/Standardization

- Torque Transducer
 - ✓ Verify with reference fluid at ambient temperature
 - ✓ Current practice using 25 mm plate at ambient temperature covers needed torque range
- Angular displacement transducer
 - ✓ Not performed in user laboratory
- Temperature transducer
 - ✓ 25 mm diameter wafer (thermistors/platinum film)
 - ✓ Questionable for 8 mm PP, Unacceptable for 4 mm PP
- Machine compliance
 - ✓ Instrument and fixture specific



2. Issues - Specimen preparation

- ❑ Placement of sample on plates – requires new protocol
 - ✓ Adhesion primary concern
 - ✓ Requires heat at binder-plate interface
 - ✓ Significant for 8 mm, Critical for 4 mm
- ❑ Trimming – Current protocol with more care
 - ✓ Hot knife/scraping tool/torch or heat gun
- ❑ Bulge and specimen dimensions – requires new protocol
 - ✓ Temperature at which bulge and final gap is formed
 - ✓ Control of normal forces during final closure
- ❑ Two protocols: WRI and MTE
 - ✓ Primary difference in bulge formation
 - ✓ Two procedures need to be refined and evaluated






MTE Protocol

- ❑ Place sample on the end of warm spatula.
- ❑ Heat upper and lower plate with a small torch.
- ❑ Press specimen on the bottom plate so that it adheres to the bottom plate.
- ❑ Lower the upper plate so that it is embedded in the test specimen so gap is $\approx 3,000 \mu\text{m}$, initial trim at $\approx 10^\circ\text{C}$.
- ❑ Reduce gap to $\approx 3,000 \mu\text{m}$ at $\approx 1^\circ\text{C}$ for final trimming
- ❑ Close to final gap at $\approx 1^\circ\text{C}$

Note: Normal force is controlled during process of trimming and gap closure

MTE - Photographs







WRI Protocol

- ❑ Using direct transfer of warm binder with spatula
 - ✓ Scoop annealed sample with spatula, no silicone mold
- ❑ Heat sample on spatula with heat gun to transfer to lower plate
 - ✓ Smear residue remaining on spatula on upper plate
- ❑ Loading and trim at 50°C - 60°C with 2 mm gap
- ❑ Closing Bulge at 30°C to 1.75 mm
- ❑ Cool to test temperature
 - ✓ Automatic adjust gap to control normal forces
 - ✓ Final gap will vary – calculate on actual gap

WRI Photographs





3. Issues - Conditioning prior to testing

Wait time

- ✓ Need to establish time increment required to reach specimen thermal equilibrium once DSR reaches thermal equilibrium
- ✓ Above increment plus “cushion” = wait time
- ✓ Use protocol established for 8 and 25 mm plates
- ✓ Times for 4 mm similar to 8 and 25 mm plates, ± 2 min

Physical hardening?


- Considered with BBR and needs to be resolved for PP
- Appears to be rheometer –specific
- Being evaluated as part of wait time considerations

Protocol for establishing wait time

New procedure added to AASHTO 315

Monitor G^* vs. time

Constant G^* \rightarrow Specimen thermal equilibrium





4. Issues - Testing Sequence

- ❑ Temperature sequencing

- ✓ Cool to highest test temperature in test sequence, decrease temperature to lower temperatures
- ✓ Cool to lowest test temperature in test sequence, increase temperature to higher temperatures
- ✓ Two sequences yield different test data, data quality



5. Issues – Linear region

- ❑ Protocol is based on linear behavior
 - ✓ How do we ensure linear behavior?
 - ✓ Specify strain limits?
 - ✓ Perform strain sweeps?
- ❑ Specify strain as function of modulus

TEMP	MEDIAN COMPLEX MODULUS, Pa	MEDIAN TORQUE, $\mu\text{N}\cdot\text{m}$	MTE TARGET % STRAIN	WRI TARGET % STRAIN
-40	1.22E+09	680	0.005	0.0015
-30	9.60E+08	540	0.005	0.0025
-20	5.60E+08	1738	0.02	0.005
-10	2.50E+08	1625	0.05	0.02
0	8.40E+07	1125	0.1	0.075
10	2.20E+07	590	0.2	0.25
20	5.20E+06	670	1	1
30	1.20E+06	300	2	2.5
40	3.00E+05	135	4	5
50	8.20E+04	50	5	10
60	2.00E+04	50	6	30






6. Issues: Verifying data integrity

- ❑ Fall-off in G^* with strain in strain sweep
- ❑ Lissajous Figures in isothermal test with varying frequency
- ❑ First and third Harmonics in isothermal test with varying frequency
- ❑ Not looking at Black Space or mastercurve construction at this point
 - ✓ Subject for later follow-on studies

Lissajous Figures

Frequency = 1 Hz
T = 28°C
PG 76 - 16






Harmonic Analysis

□ Manfred Wilhelm

- ✓ Analysis of harmonics
- ✓ Used ratio of 1st and 3rd to validate data integrity
- ✓ Patented analysis???

Wilhelm, M., *Macromolecular Materials and Engineering*
2002, 287, No. 2





Results Step 1 – Testing Protocol

- ❑ Machine compliance
 - ✓ Resolved - Responsibility on manufacturer
- ❑ Sample preparation protocol
 - ✓ In progress
 - ✓ (2 Binders) x (WRI-MTE Protocols) x (Gap vs. Normal Control) x (3 Labs/Manufacturers)
- ❑ Temperature sequencing
 - ✓ Upcoming
- ❑ Protocol for evaluating data integrity
 - ✓ Upcoming



Specific Work Elements, cont'd

- ❑ 2nd Step: Ruggedness Testing
 - ✓ Develop testing plan
 - ✓ Conduct plan using resources of Task Force
- ❑ 3rd Step: Round-Robin Testing
 - ✓ Develop testing plan
 - ✓ Need more players to execute
- ❑ Training element
 - ✓ Many will need to “step up” proficiency to use 4 mm PP
 - ✓ Formal means of technology transfer will be required



Summary – Expected results

- ❑ Recommended protocol for using 4 mm and 8 mm PP geometry in dynamic shear
 - ✓ Testing protocols in specification format
 - ✓ Equipment requirements
- ❑ Ruggedness testing program
 - ✓ Expect to include rheometers from 3 manufacturers
 - ✓ Somewhat more robust than typical ruggedness program
- ❑ Recommendations for training
 - ✓ Needed before round robin to develop sufficient number of laboratories for robust round robin
- ❑ Round robin recommendations



Expanded Working Group

- ❑ Tom Bennert — Rutgers
- ❑ Kriz Pavel — BSA - Asphalt
- ❑ Ed Trujillo — CODOT
- ❑ Horst Winter — UMass
- ❑ Olli-Ville Laukkanen — UMass
- ❑ Three rheometer manufacturers
 - ✓ Intimately involved to date
 - ✓ Cooperation is greatly appreciated
- ❑ Group will be expanded slowly as work of task force continues